

# Guidance on integrity testing for offshore installation temporary refuges

GUIDANCE ON INTEGRITY TESTING FOR  
OFFSHORE INSTALLATION TEMPORARY REFUGES

First edition

June 2017

Published by

**Energy Institute, London**

The Energy Institute is a professional membership body incorporated by Royal Charter 2003  
Registered charity number 1097899

The Energy Institute (EI) is the chartered professional membership body for the energy industry, supporting over 23 000 individuals working in or studying energy and 250 energy companies worldwide. The EI provides learning and networking opportunities to support professional development, as well as professional recognition and technical and scientific knowledge resources on energy in all its forms and applications.

The EI's purpose is to develop and disseminate knowledge, skills and good practice towards a safe, secure and sustainable energy system. In fulfilling this mission, the EI addresses the depth and breadth of the energy sector, from fuels and fuels distribution to health and safety, sustainability and the environment. It also informs policy by providing a platform for debate and scientifically-sound information on energy issues.

The EI is licensed by:

- the Engineering Council to award Chartered, Incorporated and Engineering Technician status;
- the Science Council to award Chartered Scientist status, and
- the Society for the Environment to award Chartered Environmentalist status.

It also offers its own Chartered Energy Engineer, Chartered Petroleum Engineer and Chartered Energy Manager titles.

A registered charity, the EI serves society with independence, professionalism and a wealth of expertise in all energy matters.

This publication has been produced as a result of work carried out within the Technical Team of the EI, funded by the EI's Technical Partners. The EI's Technical Work Programme provides industry with cost-effective, value-adding knowledge on key current and future issues affecting those operating in the energy sector, both in the UK and internationally.

For further information, please visit <http://www.energyinst.org>

The EI gratefully acknowledges the financial contributions towards the scientific and technical programme from the following companies

Apache North Sea	Repsol Sinopec
BP Exploration Operating Co Ltd	RWE npower
BP Oil UK Ltd	Saudi Aramco
Centrica	Scottish Power
Chevron North Sea Ltd	SGS
Chevron Products Company	Shell UK Oil Products Limited
CLH	Shell U.K. Exploration and Production Ltd
ConocoPhillips Ltd	SSE
DCC Energy	Statkraft
DONG Energy	Statoil
EDF Energy	Tesoro
ENGIE	Taq Bratani
ENI	Total E&P UK Limited
E.ON UK	Total UK Limited
ExxonMobil International Ltd	Tullow Oil
Innogy	Uniper
Kuwait Petroleum International Ltd	Valero
Maersk Oil North Sea UK Limited	Vattenfall
Nexen CNOOC	Vitol Energy
Phillips 66	Woodside
Qatar Petroleum	World Fuel Services

However, it should be noted that the above organisations have not all been directly involved in the development of this publication, nor do they necessarily endorse its content.

Copyright © 2017 by the Energy Institute, London.

The Energy Institute is a professional membership body incorporated by Royal Charter 2003.

Registered charity number 1097899, England

All rights reserved

No part of this book may be reproduced by any means, or transmitted or translated into a machine language without the written permission of the publisher.

ISBN 978 0 85293 969 7

Published by the Energy Institute

The information contained in this publication is provided for general information purposes only. Whilst the Energy Institute and the contributors have applied reasonable care in developing this publication, no representations or warranties, express or implied, are made by the Energy Institute or any of the contributors concerning the applicability, suitability, accuracy or completeness of the information contained herein and the Energy Institute and the contributors accept no responsibility whatsoever for the use of this information. Neither the Energy Institute nor any of the contributors shall be liable in any way for any liability, loss, cost or damage incurred as a result of the receipt or use of the information contained herein.

Hard copy and electronic access to EI and IP publications is available via our website, <https://publishing.energyinst.org>.

Documents can be purchased online as downloadable pdfs or on an annual subscription for single users and companies.

For more information, contact the EI Publications Team.

e: [pubs@energyinst.org](mailto:pubs@energyinst.org)

## CONTENTS

	Page
<b>Foreword</b> .....	<b>6</b>
<b>Acknowledgements</b> .....	<b>7</b>
<b>Dedication</b> .....	<b>8</b>
<b>1 Introduction</b> .....	<b>9</b>
<b>2 Scope</b> .....	<b>10</b>
<b>3 Application</b> .....	<b>11</b>
<b>4 Technical detail</b> .....	<b>12</b>
4.1 Discussion on test procedures .....	12
4.1.1 Existing standards. ....	12
4.1.2 Pressurisation tests .....	12
4.1.3 Air change rates and TR volume .....	12
4.1.4 Applied pressure and air leakage rate .....	14
4.1.5 Failure criterion .....	15
4.1.6 Range of pressures used to determine air leakage .....	15
4.1.6.1 Multiple point method .....	16
4.1.6.2 Single point method .....	16
4.1.6.3 Preferred method .....	16
4.1.7 Frequency of tests .....	16
4.1.8 Consistency between tests .....	17
4.1.9 Passive fire protection implications for applied sealing measures .....	17
4.1.10 Planning, training and experience .....	17
4.1.11 Modifications to existing TRs .....	18
4.1.12 New TRs on existing installations and TRs on new installations .....	18
4.1.13 Outdated concepts .....	18
4.2 Test conditions .....	19
4.3 Environmental concerns .....	19
4.3.1 Stability of pressure readings .....	19
4.3.2 Bias pressure .....	20
4.3.3 Stack effect .....	20
4.3.4 Limiting environmental conditions .....	21
4.3.5 Standard conditions .....	21
<b>5 Test procedure</b> .....	<b>22</b>
5.1 Determine the limiting air change rate criterion .....	22
5.2 Survey .....	22
5.3 Pre-test actions .....	22
5.4 Initial test measurements .....	23
5.5 Pressurisation tests .....	24
5.6 Check initial measurements .....	24
5.7 Check air leakage at defined differential pressure .....	25
5.8 Remedial actions and re-test .....	25

**Contents continued**

	<b>Page</b>
5.9 Post pressurisation test actions .....	25
5.10 Data manipulation and reporting .....	26
<b>6 Data analysis .....</b>	<b>27</b>
6.1 Determine the induced differential pressure .....	27
6.2 Adjust air flow rates for manufacturer's calibration .....	27
6.3 Adjust air flow rates for internal and external temperatures .....	27
6.4 Plot the results for each test .....	28
6.5 Convert to standard conditions .....	28
6.6 Characteristic air leakage rate .....	29
6.7 Determine pass/fail .....	29
<b>7 Report .....</b>	<b>30</b>
<b>Annexes</b>	
<b>Annex A Use of English .....</b>	<b>31</b>
<b>Annex B Test method theory .....</b>	<b>32</b>
<b>Annex C Sample test record sheet .....</b>	<b>34</b>
<b>Annex D Air density calculation .....</b>	<b>36</b>
<b>Annex E References .....</b>	<b>37</b>
<b>Annex F Glossary .....</b>	<b>38</b>
<b>Annex G Abbreviations .....</b>	<b>42</b>

## LIST OF FIGURES

<b>Figures</b>		<b>Page</b>
Figure 1	Example of the effect of air change rate on the atmosphere within a TR, showing the concentration of gas inside the TR (C) normalised by the exterior concentration varying with time . . . . .	13
Figure B.1	Example of positive and negative pressurisation tests. . . . .	32

## FOREWORD

This guidance has been developed by the Energy Institute (EI) Steering Group on temporary refuge (TR) integrity testing and has been researched and written by MMI Engineering (MMI).

The objective is to provide a single methodology for testing and reporting the integrity of offshore TRs with regard to air leakage rate and the potential for ingress of gas or smoke.

The intended users of this guidance are duty holders and all persons involved in the operation, testing and maintenance of offshore temporary refuges. This will typically include the owner/operator of the offshore platform where the TR is located, the offshore installation manager, offshore maintenance engineer/technicians, offshore safety engineer and any independent test organisations which may carry out integrity testing on the TR.

The guidance is intended primarily for use in the United Kingdom (UK) offshore industry.

Whilst written in the context of the UK legislative and regulatory framework, the principles set out in this publication can similarly be applied in other countries, providing national and local statutory requirements are complied with. Where the requirements differ, the more stringent should be adopted. A similar legislative and regulatory framework generally applies elsewhere in the European Communities.

## ACKNOWLEDGEMENTS

Fatima Al-Aidaroos	BG Group
Peter Bamforth	BG Group
Mike Bilio	Health and Safety Executive
Martin Brearley	Health and Safety Executive
Sam Dalziel	ConocoPhillips
Peter Gedge	BP
Kieran Glynn	BP
Ayssar Hanza	BP
Keith Lewis	Total E&P UK Ltd
Marc McBride	Centrica
Sumeet Pabby	BG Group
Tony Peakin	Total E&P UK Ltd
Michael Skidmore	BG Group
Donald Smith	ENI
Chris Venn	Chevron
Martin Worth	Plant Integrity Management
Chui-Fen Wu	Talisman

This guidance was coordinated and managed by Dr Cameron Stewart, EI, Upstream Technical Manager.



## **DEDICATION**

This first edition guidance is dedicated to Keith Lewis, process safety professional and valued colleague, who did much to pass on his wealth of experience and to lead 'younger' process safety professionals across the industry.

# 1 INTRODUCTION

A TR provides an important component of safety on an offshore platform and the Cullen Report into the Piper Alpha disaster recommended that a TR should be provided on all offshore installations. Most offshore safety cases attribute high availability and survivability of the TR as a key component in establishing an acceptable risk profile for the installation.

The UK Health and Safety Executive (HSE) document *Assessment principles for offshore safety cases*, Principle 22 defines the TR as: 'a place where personnel can muster safely in an emergency, monitor and assess the developing situation, and either take control action or initiate evacuation'. The TR provides protection from credible fire and explosion scenarios and has some sealing function to prevent excessive air outflow and ingress of toxic smoke and gases. The key component of the TR which provides the sealed environment is usually the Heating, Ventilation and Air Conditioning (HVAC) fire dampers. Other potential air leakage paths include door seals, windows, cable and pipe penetrations, water traps and degradation of the TR structure itself.

Ongoing assurance of a TR's physical integrity against smoke and gas ingress is therefore a critical activity. Proper integrity testing should demonstrate the effectiveness of the TR to protect personnel from the effects of fire, smoke and toxic fumes during a major incident as required by the Offshore Installations (safety case directive) (Safety Case etc) Regulations 2015. The effectiveness of this depends on the ability of the TR boundary to withstand the hazards associated with these events, including blast, impact and fire.

A number of national, international and industry bodies have released methodologies for leakage testing and permeability assessment of onshore buildings and rooms. However, before the issue of this guidance there was no test standard or guidance specific to the offshore industry. Furthermore, anecdotal evidence from offshore operators pointed clearly to some inconsistencies in the way such testing is carried out between test organisations and operators.

This guidance is intended to provide a standard methodology to the offshore industry to perform air-tightness testing as part of their demonstration of the integrity of the TR and on-going safety management procedure.

## 2 SCOPE

This guidance is intended for application to testing offshore installation TRs only.

It may also be used to test leakage properties of other enclosed spaces on offshore installations, although in this case the definition of test pressures and limiting leakage rates may need to be adjusted to suit the duty of the particular enclosure.

This guidance note is not applicable to testing onshore buildings or enclosures as the environmental conditions are likely to be significantly different. In this instance the relevant British Standard is BS EN 13829:2001 *Thermal performance of buildings* and the guidance therein may be appropriate depending on the function of the building.

### **3 APPLICATION**

This guidance should be used by offshore duty holders, as part of their TR integrity assessment and maintenance procedure and by independent test organisations commissioned by offshore duty holders to carry out TR testing.

HSE Offshore Information Sheet No 1/2006 *Testing regime for offshore TR-HVAC fire dampers and TR pressurization requirements, 2007* recommends that TR pressurization tests are carried out at a frequency of no less than three years and preferably every two years. Duty holders may require tests more frequently than every two years to build up sufficient data to understand the reduction in performance of the TR over a period of time and the effect of environmental conditions on TR performance.