

Guidance on selection, installation and management
of fire-resistant sealant materials and system components
for secondary containment construction/expansion joints

GUIDANCE ON SELECTION, INSTALLATION AND MANAGEMENT OF
FIRE-RESISTANT SEALANT MATERIALS AND SYSTEM COMPONENTS FOR
SECONDARY CONTAINMENT CONSTRUCTION/EXPANSION JOINTS

First edition

July 2019

Published by
Energy Institute, London

The Energy Institute is a professional membership body incorporated by Royal Charter 2003
Registered charity number 1097899

The Energy Institute (EI) is the chartered professional membership body for the energy industry, supporting over 20 000 individuals working in or studying energy and 200 energy companies worldwide. The EI provides learning and networking opportunities to support professional development, as well as professional recognition and technical and scientific knowledge resources on energy in all its forms and applications.

The EI's purpose is to develop and disseminate knowledge, skills and good practice towards a safe, secure and sustainable energy system. In fulfilling this mission, the EI addresses the depth and breadth of the energy sector, from fuels and fuels distribution to health and safety, sustainability and the environment. It also informs policy by providing a platform for debate and scientifically-sound information on energy issues.

The EI is licensed by:

- the Engineering Council to award Chartered, Incorporated and Engineering Technician status, and
- the Society for the Environment to award Chartered Environmentalist status.

It also offers its own Chartered Energy Engineer, Chartered Petroleum Engineer, and Chartered Energy Manager titles.

A registered charity, the EI serves society with independence, professionalism and a wealth of expertise in all energy matters.

This publication has been produced as a result of work carried out within the Technical Team of the EI, funded by the EI's Technical Partners. The EI's Technical Work Programme provides industry with cost-effective, value-adding knowledge on key current and future issues affecting those operating in the energy sector, both in the UK and internationally.

For further information, please visit <http://www.energyinst.org>

The EI gratefully acknowledges the financial contributions towards the scientific and technical programme from the following companies:

| | |
|------------------------------------|---|
| Andeavor | Phillips 66 |
| BP Exploration Operating Co Ltd | Qatar Petroleum |
| BP Oil UK Ltd | Repsol Sinopec |
| Centrica | RWE npower |
| Chevron North Sea Ltd | Saudi Aramco |
| Chevron Products Company | Scottish Power |
| Chrysaor | SGS |
| CLH | Shell UK Oil Products Limited |
| ConocoPhillips Ltd | Shell U.K. Exploration and Production Ltd |
| DCC Energy | SSE |
| EDF Energy | TAQA Bratani |
| ENI | Total E&P UK Limited |
| E.ON UK | Total UK Limited |
| Equinor | Tullow Oil |
| ExxonMobil International Ltd | Uniper |
| Innogy | Valero |
| Kuwait Petroleum International Ltd | Vattenfall |
| Nexen CNOOC | Vitol Energy |
| Ørsted | Woodside |
| Perenco | World Fuel Services |

However, it should be noted that the above organisations have not all been directly involved in the development of this publication, nor do they necessarily endorse its content.

Copyright © 2019 by the Energy Institute, London.

The Energy Institute is a professional membership body incorporated by Royal Charter 2003.

Registered charity number 1097899, England

All rights reserved

No part of this book may be reproduced by any means, or transmitted or translated into a machine language without the written permission of the publisher.

ISBN 978 1 78725 107 6

Published by the Energy Institute

The information contained in this publication is provided for general information purposes only. Whilst the Energy Institute and the contributors have applied reasonable care in developing this publication, no representations or warranties, express or implied, are made by the Energy Institute or any of the contributors concerning the applicability, suitability, accuracy or completeness of the information contained herein and the Energy Institute and the contributors accept no responsibility whatsoever for the use of this information. Neither the Energy Institute nor any of the contributors shall be liable in any way for any liability, loss, cost or damage incurred as a result of the receipt or use of the information contained herein.

Hard copy and electronic access to EI and IP publications is available via our website, <https://publishing.energyinst.org>.

Documents can be purchased online as downloadable pdfs or on an annual subscription for single users and companies.

For more information, contact the EI Publications Team.

e: pubs@energyinst.org

CONTENTS

| | Page |
|--|-----------|
| Acknowledgements | 7 |
| Foreword | 8 |
| 1 Introduction, scope and application | 10 |
| 1.1 Introduction | 10 |
| 1.2 Scope | 11 |
| 1.3 Application | 11 |
| 2 Industry requirements | 13 |
| 2.1 Current (PSLG) guidance on requirements for sealing secondary containment construction/expansion joints | 13 |
| 2.2 Constructional requirements | 13 |
| 2.2.1 New builds | 13 |
| 2.2.2 Retrofitting to existing installations. | 14 |
| 2.3 Liquid retention requirements to maintain secondary containment. | 16 |
| 2.4 Fire resistance requirements. | 16 |
| 3 Generic types of sealant systems | 18 |
| 3.1 System overview | 18 |
| 3.2 Sealant material chemistries. | 19 |
| 3.2.1 Intumescent polysulfide-based materials. | 19 |
| 3.2.2 Polyurethane/silyl modified polymer (SMP) sealants. | 20 |
| 3.2.3 Compressible intumescent strips. | 20 |
| 3.2.4 Silicone sealants | 20 |
| 3.2.5 Phenolic syntactic foam/glass reinforced laminates | 20 |
| 3.2.6 Combined materials | 21 |
| 3.3 Joint sealant system components | 21 |
| 3.3.1 Primers. | 21 |
| 3.3.2 Two part and multi-pack materials | 21 |
| 3.3.3 Joint filler materials/backers | 22 |
| 3.3.4 Steel cover plates/additional protection | 22 |
| 4 Performance criteria, standards and sealant system specification | 23 |
| 4.1 Applicable standards and guidance | 23 |
| 4.1.1 Fire resistance test data and limitations. | 23 |
| 4.1.2 CIRIA R736 | 23 |
| 4.2 Key performance criteria | 24 |
| 4.2.1 External use (UV resistance) | 24 |
| 4.2.2 Hydrocarbon resistance | 24 |
| 4.2.3 Water (firewater) resistance | 24 |
| 4.2.4 Hydrocarbon fire resistance | 25 |
| 4.2.5 Adhesivity to substrates (e.g. concrete, earth, steel, pipework, new and existing substrates etc.) and movement flexibility | 25 |
| 4.2.6 Longevity/sustainability. | 25 |

Contents continued

| | Page |
|--|-------------|
| 4.3 Detailed specification guidance | 26 |
| 4.3.1 Functionality | 26 |
| 4.3.2 Availability and reliability | 27 |
| 4.3.3 Survivability | 27 |
| 4.3.4 Physical properties specification | 28 |
| 4.3.5 Liquid retention specification | 28 |
| 4.3.6 Resistance to external factors | 29 |
| 4.4 Quality control | 30 |
| 4.4.1 Materials quality | 30 |
| 4.4.2 Installation quality | 31 |
| 4.4.3 Guidelines for installation | 31 |
| 4.5 Inspection and maintenance of sealant systems | 35 |
| 4.5.1 Demonstrating ongoing integrity | 36 |
| 4.5.2 Inspection of sealant systems/joints | 36 |
| 4.5.3 Maintenance of integrity | 36 |
| 4.5.4 Visual inspection and remedial action | 37 |
| 4.6 Lifecycle management/decommissioning/waste management | 38 |
| 4.7 Emergency response implications | 39 |
| 4.7.1 Fire resistance, integrity of sealant system/joint and safety | 39 |
| 4.7.2 Addition of firefighting media (firewater/foam) to secondary containment – implications | 39 |
| 4.7.3 Thermal decomposition and by-products | 40 |
| 4.7.4 Guidance to maximise seal integrity under fire conditions | 40 |
| 4.7.5 Tertiary containment issues – emergency planning guidance | 41 |
| 4.8 Typical fire resistance durations | 41 |
| 4.8.1 Fire resistance (furnace) test data – sealants/backers only | 42 |
| 4.8.2 Fire resistance test data | 42 |
| 4.9 Typical liquid retention durations | 46 |
| 4.9.1 Sealant systems unexposed to fire | 47 |
| 4.9.2 Sealant systems exposed to fire (single, double face and with steel cover plate) | 47 |
| 4.9.3 Typical liquid retention durations | 47 |
| 4.9.4 Typical liquid loss | 48 |

Annexes

| | | |
|----------------|--|-----------|
| Annex A | Glossaries of terms, acronyms and abbreviations | 49 |
| | A.1 Introduction | 49 |
| | A.2 Glossary of terms | 49 |
| | A.3 Glossary of acronyms and abbreviations | 50 |
| Annex B | References and bibliography | 52 |
| | B.1 References | 52 |
| | B.2 Bibliography | 52 |
| Annex C | Quality assurance of sealants | 54 |

Contents continued

| | Page |
|--|-------------|
| Annex D Media pack | 59 |
| D.1 Introduction | 59 |
| D.2 Link to access media pack | 59 |
| D.3 Media pack content | 59 |
| D.3.1 Slide pack | 59 |
| D.3.2 Test videos | 59 |

LIST OF FIGURES, TABLES AND PHOTOGRAPHS

| | Page |
|--------------------|--|
| Figures | |
| Figure 1 | Plan view of a typical new build construction/expansion joint seal fitted with steel waterstop (replicated from HSE PSLG Final report) 14 |
| Figure 2 | Plan view of a typical retrofit/remediation construction/expansion joint seal fitted with steel cover plate (replicated from HSE PSLG Final report) 15 |
| Figure 3 | Plan view of a typical unprotected/exposed expansion joint with sealant only 15 |
| Figure 4 | Standard/cellulosic and hydrocarbon time temperature curves 17 |
| Tables | |
| Table 1 | Typical fire resistance levels for different joint configurations 28 |
| Table 2 | Example supplier fire resistance data for joint configurations and dimensions. 33 |
| Table 3 | Typical fire resistance times for sealants (standard furnace testing) 42 |
| Table 4 | Typical fire resistance times for sealants (single joint, with no liquid hydrocarbon behind seal) 43 |
| Table 5 | Typical fire resistance times for sealants (single joint, with liquid hydrocarbon behind seal). 43 |
| Table 6 | Typical fire resistance times for sealants (single joint, hydrocarbon fire testing) 45 |
| Photographs | |
| Photo 1 | Overview of sealant system components 19 |
| Photo 2 | Steel cover plate installed on single face of a joint 22 |
| Photo 3 | Cherry red glow of steel cover plate after 6 hours of fire exposure. 45 |
| Photo 4 | Excavation of joint system/sealant (intumescent polysulfide) following >6 hour fire exposure (front view) 46 |

ACKNOWLEDGEMENTS

This technical publication was commissioned by EI's Containment Systems Working Group (CSWG), which is a working group of the EI's Process Safety Committee. Development work was contracted initially to Resource Protection International (RPI), which was acquired by Falck Fire Consulting. Final work was carried out by ENRg Consultants. Paul Watkins was the main researcher throughout the project phases; Dr Barbara Chisholm supported the project. CSWG members provided technical direction to the project. Its members during the project were:

| | |
|------------------------------|---|
| Katy Baker | Arcadis |
| Dr Colin Cartwright | Atkins |
| Dave Wright | BP |
| Stephen Clarke | BP |
| Kerry Sinclair (Secretary) | Energy Institute |
| Dr Mark Scanlon | Energy Institute |
| Paul Watkins | ENRg Consultants |
| David Tarttelin (Vice-Chair) | Environment Agency (EA) |
| Mark Palmer | Esso Petroleum Company Ltd |
| Tony Brown | Federation of Petroleum Suppliers (FPS) |
| Tammy Brantley | GB Oils |
| Liz Copeland | IKM Consulting |
| Steven Flynn | Rawell Environmental Ltd |
| Brian Blagden | Scottish Environment Protection Agency (SEPA) |
| Dr Irene Anders | Scottish Environment Protection Agency (SEPA) |
| Leighanne Moir | Scottish Environment Protection Agency (SEPA) |
| Felix Nelson | Shell |
| Barrie Salmon | Tank Storage Association (TSA) |
| John Wormald | Total Lindsey Oil Refinery |
| Jamie Walker | UKPIA |
| Ian Goldsworthy (Chair) | Valero |

The EI wishes to record its appreciation of the work carried out by the researchers and also its gratitude for the valuable contributions made by CSWG members during the course of the project. Dr Mark Scanlon managed the project, assisted by Kerry Sinclair. Laszlo Komaromi edited the draft in preparation for publication.

Affiliations refer to the time of participation.

FOREWORD

This technical publication has been prepared under the technical direction of the Energy Institute's (EI) Containment Systems Working Group (CSWG) adopting the findings from the *Research report: Fire resistance testing of sealant materials and system components for secondary containment construction/expansion joints* (hereafter *Research report*). It is primarily intended for application in the United Kingdom (UK) since it refers to the Control of Major Accident Hazards (COMAH) Competent Authority (CA) *Policy on containment of bulk hazardous liquids at COMAH establishments* (hereafter *Containment policy*). However, this technical publication may also be relevant for facilities and markets outside of the UK.

The *Research report* is a comprehensive document detailing the experimental work carried out to investigate the fire resistance duration and liquid retention capabilities/integrity of sealant systems used under real world fire exposure conditions. This accompanying technical publication integrates information from product data sheets (PDS) to provide guidance on installation, inspection, maintenance and life cycle considerations.

The main conclusions relating to these and from the EI fire testing investigations are:

- A variety of fire-resistant (FR) sealant materials are available for use in secondary containment construction/expansion joints. In the EI fire testing programme investigations of remediation type joints were tested (i.e. comprising of backer, sealant, intumescent foil backed sponge strip and Process Safety Leadership Group [PSLG] recommended steel cover plate described in *Final report: Safety and environmental standards for fuel storage sites*, hereafter PSLG *Final report*).
- Some sealant products on the market are not specifically designed for application to vertical and/or horizontal bund wall gaps and this was evidenced during installation of the fire tested joints. Specifiers and end users should select a FR sealant that is conducive to installation as well as one that offers good fire resistance.
- Various sealant materials are damaged by exposure to a hydrocarbon fire without the protection afforded by a steel cover plate, and their liquid retention effectiveness is reduced. However, even with a steel cover plate there will be significant damage to the seal due to long heat exposure and spalling of concrete, such that its integrity may eventually fail, leading to liquid leakage from the secondary containment.
- In general, all sealants exposed to hydrocarbon fires during the EI test work failed within 2–3 hours when the seal was installed on a single side of a bund mock-up module.
- Seals were partially consumed or extensively damaged above the liquid level in the bund module mock-ups, even with steel cover plates installed as additional protection.
- There are implications of adding firewater and/or foam to a bund fire in progress – as the liquid level rises it will encounter the damaged portion of the joint and push any sealant material outwards, increasing the possibility of loss of containment from the bund.
- There are various installation considerations that require thought and the quality of installation is highly likely to affect fire performance.
- The type of backing material used in the joint plays an important role in maintaining integrity of the seal in front. Ceramic fibre (CF) backers appear to be more robust following fire exposure and resistant to the passage of liquid through secondary containment gaps.

- Under fire exposure conditions all the joints fire tested were seen to emit potentially noxious fumes from time to time – fire responders should be aware of this hazard. Additionally, steam ejection can easily weaken or dislodge backing materials on the unexposed side of the joint and eventually push them outwards, reducing integrity of the sealant system.
- Approximately 35–55 % liquid losses from secondary containment were measured for all products, arising from liquid loss along the damaged portion of the joint during post fire exposure hydrostatic testing when left to stand overnight. The lowest levels of liquid loss were not necessarily observed for products that are the most commonly specified and used. Joints tested without a steel cover plate generally failed to retain liquid during the tests. Therefore, the presence of a steel cover plate helped retain liquid in the bund module mock-ups.
- Where sealants are applied to one side of a bund module mock-up gap there is only a 2-hour response window for joint failure should be given in the case of a fire incident. Where sealants are applied to both sides and robust backing materials are used such as CF, 6 hours or more fire resistance may be possible, although this depends on installation quality. After this time, fire response personnel should monitor closely for signs of loss of integrity and loss of containment. Supplier specifications typically quote 5 hours possible with a double seal arrangement.
- Fire authorities should be involved with the planning preparation in the case of an incident. Fire authorities should be made aware of the risks involved when adding fire water to secondary containment where seals are exposed to fire and plan for the consequences, as added firewater can weaken and dislodge seals that are already weakened by the fire. Liquid loss was substantially reduced under fire conditions when firewater was not applied to the bund module mock-up fire. In cases where liquid might be lost due to fire control actions, facility operating companies and fire responders should consider what tertiary containment measures might be necessary.
- Where steel cover plates are utilised for additional protection there is a possibility of re-ignition of the fire with potential large-scale re-establishment if any applied foam blanket is not secure; this is because the cover plate glows red hot during after a fire exposure and can easily reignite hydrocarbon vapours.
- In practice, during most bund fire incidents it is highly likely that atmospheric storage tank (AST) cooling water systems will be operated to limit the consequences of fire exposure and decrease the possibility of fire escalation. This addition of fire water may weaken the fire exposed seal and fire water run-off may be lost from secondary containment. Therefore, fire responders should pre-plan and consider the vulnerability of the bund and any joints/seals to cracking if water/foam is applied. It is likely that fixed or semi fixed foam systems for bund fire-fighting would minimise the volumes of water added to a bund and lessen the chances of bund/seal damage.

It is hoped that the general findings above offer some useful guidance to designers, specifiers, end users and emergency responders when implementing FR sealants within seal systems for secondary containment applications. For further information on the testing see *Research report*.

1 INTRODUCTION, SCOPE AND APPLICATION

| Reference – <i>Research report: Fire resistance testing of sealant materials and system components for secondary containment construction/expansion joints</i> | |
|---|---|
| Section(s) and title(s) | 1 Introduction 2 Test scope |
| Description/scope | The introduction and scope of the <i>Research report</i> describe the intent of the test work and the scope of the fire resistance testing: <ul style="list-style-type: none"> – why it was carried out – how it was carried out – what materials were tested based on the results of EI/stakeholder initial product surveys |

1.1 INTRODUCTION

The selection of appropriate sealant materials and system components in secondary containment expansion joints becomes critical in case of a major fire accident. The 2005 Buncefield fuel storage incident demonstrated the consequences of using inadequate sealant materials. Reports following the incident found that the integrity/fire resistance of sealant materials play an important role in preventing the spread of fire beyond the secondary containment bund area.

Based on a series of fire exposure tests (see *Research report*) this technical publication aims to make industry practitioners (e.g. designers and bulk storage facility managers) intelligent customers of the various commercially available bund sealant materials and configurations used to provide fire resistance and leak tightness in secondary containment (i.e. bund) wall construction/expansion joints. In addition, it aims to assist suppliers of sealant materials and system components in understanding the various industry requirements and specifications to help optimise their products.

This guidance adopts findings from the *Research report*. The *Research report* is a comprehensive document detailing the experimental work carried out to investigate the fire resistance duration and liquid retention capabilities/integrity of sealant systems used under real-world fire conditions.

The objective of the tests was to investigate the fire resistance duration of the sealant materials and system components used under real-world fire conditions as opposed to standardised furnace testing. The criteria for success were inherent fire resistance of the test materials whilst also maintaining the water tightness of the joint.

The period of fire resistance and integrity was investigated with a view to providing information about the seal to the oil and petrochemical industry about these aspects over and above the information which is widely available from PDS. It was not the intention that the results of the tests should give any one sealant material and/or system component any commercial advantage by testing and publishing results. The primary aim was to furnish potential end users of the products, and the industry as a whole, with independently assessed information relating to the fire resistance and integrity of the sealants for situations where

extended periods of fire resistance are required – such as in large, long duration secondary containment bund fires.

Designers, specifiers, end users and emergency responders may use the guidance in this publication to select appropriate system(s) and the tables in Section 4 can be studied to identify the required system that aligns to their performance requirements.

1.2 SCOPE

The aim of this technical publication is to present the findings from the *Research report* concisely and with clarity for industry practitioners. Where appropriate, background information and fire exposure test data from the *Research report* is referenced at the start of each chapter. Designers, specifiers and end users should therefore refer to this if more information is required regarding the various sealant materials and system components, test parameters and fire performance.

This technical publication covers various aspects of the materials and their performance specification, including:

- generic types of sealant systems;
- criteria to include in a specification/performance standard;
- importance of surface preparation and installation quality control;
- typical fire resistance durations;
- life cycle of sealant systems;
- liquid retention duration implications, and
- limitations of guidance with comparison to PSLG requirements.

To accompany this technical publication a media pack is available (see Annex D). The pack collates visual information, including videos and photographs, which were taken during fire exposure and hydrostatic testing of the selected sealant materials and system components. It also provides concise information mirroring the guidance in this technical publication for ease of reading and reference for designers, specifiers, end users and product suppliers.

1.3 APPLICATION

The guidance contained in this technical publication is applicable both to new build installations and existing facilities. As the primary application of the guidance relates to construction/expansion joints in secondary containment bund walls it should be considered how such joints are typically sealed depending on the age of the facility, see 2.2 *Constructional Requirements*. The guidance in this technical publication is primarily intended for application in the United Kingdom (UK) since it refers to the COMAH CA *Containment policy* (see section 2) and matters arising from the Buncefield fuel storage fire in 2005. Also, some of the sealant system materials tested as part of the fire resistance testing research are either solely available or widely applied in the UK market and petroleum and bulk fuel storage sector, respectively. As there are specific constructional requirements for secondary containment construction/expansion joints recommended in the PSLG *Final report* applied at UK facilities, the guidance provided in this technical publication is particularly relevant to the UK situation.

However, this guidance may also be relevant for facilities and markets outside of the UK. At hydrocarbon storage facilities in other locations it is often observed that sealant materials and system components similar to those tested in the *Research report* are in use and whilst the specific constructional requirements applied by the UK's COMAH CA might not be followed, the guiding principles in terms of fire exposure, fire resistance, design and specification are broadly similar and relevant. For example, in some worldwide locations there is only a requirement to provide a sealant material in a secondary containment bund joint without a steel cover plate or waterstop.

Some of the other sealant materials and system components in use may differ in chemistries, composition, specification or application to those tested in the *Research report*. Therefore, whilst some of the principles contained in this guidance might apply, the non-UK reader should exercise caution in applying the guidance to specific joint configurations, check product/sealant system specifications and capabilities, and if necessary conduct additional fire testing to verify performance.

Products referred to are those that were tested, which were available commercially. They are listed in the *Research report*. The products were selected to reflect different product types and chemistries, as described in the *Research report*. Other products and bespoke solutions not tested should be evaluated using the performance criteria set out in section 4. Pipe penetration and link seal products were excluded from the testing.

It should be noted that new build joints -those featuring a steel waterstop- were not tested in the *Research report* because conceptually they should greatly reduce or eliminate the possibility of loss of containment. Some sealant materials have also been tested without steel cover plates.